```
October, 1944.
SUBJECT: Monthly Sanitary Report for September 1944.
         Commanding Officer, Fort Huachuca, Arizona.
                  Total gallons water pumped from wells- - - - 37,226,000 gals.
                  Maximum gallons water pumped per day - - - 2,213,000
                            11 11 11 11 - - - 467,000
11 11 11 11 - - - 1,240,800
                                  " from springs - - - - - 18,480,000
                  Water consumed at Fry, Arizona - - - - -
                                                                 272,000
                  Water pumped through softener at Post
                                          Laundry - - - 1,275,000
                                                                  10,727
                  Post Population- - - - - - - - - - - - - -
                  Consumption of water per capita per day --
                                                                    168
              (2) Water consumed by command is potable bacterially and chemi-
                  cally, free from objectionable taste, color and odor.
```

GHH:ml

Fort Huachuca, Arizona,

Waste Disposal:

Thru: The Post Surgeon

ENVIRONMENTAL SANITATION:

Minimum

Total

Water Supply:

(1)

ъ. c.

Housing and Tentage: Satisfactory Grading and Drainage: Satisfactory

Sewage Disposal:

(a) Plant No. I:

```
Maximum sewage treated per day - - - - Hinumum " " " - - - - Average " " " " " - - - -
                                                       729,000
                                                       132,000
                                                       575,000
     Suspended solids % removal - No samples.
     Gallons of raw sewage by-passed- - - - -
                                                            0.0 "
(b) Plant No. II:
     Total sewage treated - - - - - - -
                                                     9,258,000 "
     Maximum sewage treated per day - - - - - Minumum " " " - - - -
                                                       852,000
     Minumum "
                                                       393,000
                       T?
                                Ħ
                                                       514,000
     Average
     Suspended solids % removal - No samples
     Gallons of raw sewage by-passed- - - - -
                                                            0.0
```

Total sewage treated - - - - - - - 17,250,000 gals

OFFICE OF THE POST MEDICAL INSPECTOR

HOSPITAL

- (2) Garbage Disposal: Satisfactory
- e. Mess Sanitation: Satisfactory
- f. Insect and Rodent Control:
 - (1) Bedbugs: Periodic spraying is being continued where necessary with satisfactory results.
 - (2) Roaches: Roach extermination program is being continued with satisfactory results.
 - (3) Flies: The fly population has decreased due to destruction of breeding places and cooler weather.

g. Other Phases of Environmental Sanitation:

(1) Due to decrease in Post population, many of the eating establishments considered unsatisfactory in Fry, Arizona will discontinue operation. Post order on this subject which was reported in a previous report is still in effect.

h. Personal Hygiene:

(1) Physical inspections - included in VDCO's report attached.

(2) Venereal Disease - Report of VDCO attached.

- (3) General physical condition of command satisfactory.
 (4) Immunizations: Smallpox-105 Typhoid-137 Tetanus-135
- 3. UNDUE PREVALENCE OF COMMUNICABLE DISEASE: NONE
- 4. MEN & IMPROVED MEASURES AND DEVICES: None
- 5. VETERIMARY REPORT: Report of Veterinary Officer is attached.
- 6. FOOL & NUTRICION: Report of Nutrition Officer is attached.
- 7. RECOMMENDATIONS: Hone

EORGE A. HAMANN, JR., Captain, Sanitary Corps, Post Medical Inspector.

Incls: Nutrition Report
VD Report
Veterinary Report
Water Reports

-2-